STUART GROUP LTD

Used Generator Information

T: 01953 454540 F: 01953 456968
E: enquiries@stuartgroup.info
W: www.stuartgroup.co.uk
Stuart House, Hargham Road, Shropham, Norfolk, NR17 1DT

Asset Data Information

Stock Number	XP50022
Set Manufacturer	FG Wilson
Set Model	P450

Alternator Data

kVA - Prime	450
kW - Prime	360
kVA - Standby	495
kW - Standby	360
Volts	415/240
Hz	50
Amps @ Standby rating	693
Make	Stamford
Model	HCK544C
Serial No:	0110792/01
RCD	Yes
MCB | ACB	MCB 3-Pole
PMG | AREP	PMG
Heater	No

Engine Data

Make	Perkins
Model	3008-TAG3A
Serial No:	SGD080013U2711F
Hours	11002
Exhaust Type	Twin on Roof
Bellows	Yes
Voltage	24
Batteries / Battery Type	2 x Lead Acid
Battery Isolator	No
Water Jacket Heater	Yes
Lube oil top up	No
Racor Filter	Water Trap
3 Way Fuel Valve	No
Fire Drop Valve	Yes

Fuel Tank Data

Skid / Free Standing	Skid
Single Skin / Bunded	Bunded
Capacity Litres	675
Capacity Hours @ 75%	9
Fuel Gauge	Yes
Transfer Pump	Yes

Set Serial Number	E5552A / 001
Year Of Manufacture	1999
Price	£32,000.00
Date Into Stock	03/24

Enclosure Data

Open / Skid	No
Sound Attenuated	Yes
Containerised	Yes
Sound Level 75% @ 7m	
Length mm	9050 ±
Width mm	2800 ±
Height mm (excl exhaust)	2600 ±
Height mm (incl exhaust)	3350 ±
Colour	Blue / White
Condition	Good
Lighting AC / DC	Yes
Bunded Floor	Yes

Lifting Data / Chassis

Weight - Kg	TBC
Centre Point	No
Corner Lifting Points	On Container
Forklift Pockets	No
Trailer	No

Control Panel Data

Make	FG Wilson - 4001
Digital / Analog	Digital
Hour Meter	Yes
Oil	Yes
Water	Yes
Battery	Yes
Amp	Yes
Volts	Yes
Hz	Yes
AMF - Parallel	Yes
Battery Charger	Yes

Additional Data

Sockets	No

Warranty

FG WILSON Authorised Dealer

All Diesel Generators Are Inspected And Tested Prior To Dispatch