


## Used Generator Information

Asset Data Information	
Stock Number	XP150018
Set Manufacturer	MITSUBISHI
Set Model	N/A
Alternator Data	
kVA - Prime	1500
kW - Prime	1200
kVA - Standby	1650
kW - Standby	1320
Volts	415
Hz	50
Amps @ Standby rating	2293
Make	MECC ALTE
Model	EC046-1S
Serial No:	1430322
RCD	NO
MCB   ACB	ACB 4 POLE
PMG   AREP	NO
Heater	NO
Engine Data	
Make	MITSUBISHI
Model	S12R-PTA2
Serial No:	D0885
Hours	579
Exhaust Type	IN ROOF
Bellows	YES
Voltage	24
Batteries / Battery Type	6XAGM
Battery Isolator	YES
Water Jacket Heater	YES
Lube oil top up	NO
Racor Filter	YES
3 Way Fuel Valve	NO
Fire Drop Valve	No
Fuel Tank Data	
Skid / Free Standing	Free Standing in Container
Single Skin / Bunded	Single Skin
Capacity Litres	2000 ltr array
Capacity Hours @ 75%	8
Fuel Gauge	YES
Transfer Pump	NO
Set Serial Number	N/A
Year Of Manufacture	2010
Price	£92,000.00
Date Into Stock	Oct-25
Enclosure Data	
Open / Skid	SKID
Sound Attenuated	YES
Containerised	YES
Sound Level 75% @ 7m	
Length mm	6100
Width mm	2500
Height mm (excl exhaust)	2900
Height mm (incl exhaust)	3200
Colour	WHITE
Condition	GOOD
Lighting AC / DC	YES
Bunded Floor	YES
Lifting Data / Chassis	
Weight - Kg	19,200
Centre Point	NO
Corner Lifting Points	YES
Forklift Pockets	NO
Trailer	NO
Control Panel Data	
Make	DEEP SEA 8610
Digital / Analog	DIGITAL
Hour Meter	YES
Oil	YES
Water	YES
Battery	YES
Amp	YES
Volts	YES
Hz	YES
AMF - Parallel	YES
Battery Charger	YES
Additional Data	
Sockets	NO
Warranty	

Ex standby UK bank head office



Authorised Dealer

All Diesel Generators Are Inspected And Tested Prior To Dispatch