

Used Generator Information

T: 01953 454540 F: 01953 456968 E: enquiries@stuartgroup.info W: www.stuartgroup.ltd.uk

Stuart House, Hargham Road, Shropham, Norfolk, NR17 1DT

Asset Data I	
Stock Number	XP150016
Set Manufacturer	FG Wilson
Set Model	P1500
Alternator Data	
kVA - Prime	1500
kW - Prime	1200
kVA - Standby	1650
kW - Standby	1320
Volts	415
Hz	50
Amps @ Standby rating	2293
Make	Leroy Somer
Model	LL8124P
Serial No:	183771/01
RCD	No
MCB ACB	MCB 3 Pole
PMG AREP	PMG
Heater	No
Engine Data	
Make	Perkins
Model	4012 TAG 2A
Serial No:	DGB122051U8172M
Hours	
Exhaust Type	Box on roof
Bellows	Yes
Voltage	24
Batteries / Battery Type	4 x Lead Acid
Battery Isolator	No
Water Jacket Heater	Yes
Lube oil top up	Yes
Racor Filter	No
3 Way Fuel Valve	No
Fire Drop Valve	Yes
Fuel Tank Data	
Skid / Free Standing	No
Single Skin / Bunded	
Capacity Litres	
Capacity Hours @ 75%	
Fuel Gauge	
Transfer Pump	

FGWPST02HV0A00974
2005
£79,500.00
July 2023
sure Data
Skid
Yes
No
11890
3300
3700
3850
Green
Good
AC
Yes
ata / Chassis
30000
No
Yes, on chassis
No
No
l Panel Data
Genpart 6400
LED
Yes
Parallel
Yes
ional Data
No

Control panel does not show hours.

