

Used Generator Information

T: 01953 454540 F: 01953 456968 E: enquiries@stuartgroup.info W: www.stuartgroup.ltd.uk

Stuart House, Hargham Road, Shropham, Norfolk, NR17 1DT

| | Asset Data |
|------------------|------------|
| Stock Number | XP15007 |
| Set Manufacturer | FG Wilson |
| Set Model | P1500X-HV |

| mormation | | |
|---------------------|------------|--|
| Set Serial Number | C3161A/001 | |
| Year Of Manufacture | 1997 | |
| Price | £55,000.00 | |
| Date Into Stock | Jan 2022 | |

| Alternator Data | | |
|--------------------------|-----------------|--|
| kVA | 1500 Prime | |
| kW | 1200 | |
| Volts | 6600/3810 | |
| Hz | 50 | |
| Amps | 131.2 | |
| Make | Leroy Somer | |
| Model | LSA52 VL9-4P | |
| Serial No: | 164738-1 | |
| RCD | No | |
| MCB ACB | No | |
| PMG AREP | Yes | |
| Heater | Yes | |
| Engine Data | | |
| Make | Perkins | |
| Model | 4012-TAG2 | |
| Serial No: | DGB120270U0509C | |
| Hours | 1515 | |
| Exhaust | Single on roof | |
| Bellows | Yes | |
| Voltage | 24V | |
| Batteries / Battery Type | 4 x Lead Acid | |
| Battery Isolator | Yes | |
| Water Jacket Heater | Yes | |
| Lube oil top up | No | |
| Racor Filter | No | |
| 3 Way Fuel Valve | No | |
| Fire Drop Valve | No | |
| Fuel Tank Data | | |
| Skid / Free Standing | No | |
| Single Skin / Bunded | No | |
| Capacity Litres | No | |
| Capacity Hours @ 75% | No | |
| Fuel Gauge | No | |
| Transfer Pump | No | |

| Enclosure Data | | |
|------------------------|--|--|
| Skid | | |
| Yes | | |
| Yes | | |
| | | |
| 16000 | | |
| 3300 | | |
| 3300 | | |
| 5200 | | |
| White / Grey | | |
| Good | | |
| Yes | | |
| Yes | | |
| Lifting Data / Chassis | | |
| 29000 | | |
| Corner on chassis x 3 | | |
| No | | |
| No | | |
| Panel Data | | |
| FG Wilson | | |
| Yes | | |
| Yes | | |
| No | | |
| No | | |
| Yes | | |
| Additional Data | | |
| No | | |
| | | |
| | | |

Warranty 1000 hours or 6 months which ever soonest.

Previous use ex large factory site powering a HV private network at 6600 volts.

Auto start and sync.

Switch gear control room dims: 2.5 x 2.67 m.

